

Invitation of Quotation for providing

Fire Fighting Services

For Tex-Trends India 2012 Exhibition

Last Date to submit quotation	2 nd September'2011 by 1700 hrs
Quotation to be submitted to	Please send your sealed quotation addressed to: Mr. Rajiv Bhatnagar Director Apparel Export Promotion Council Apparel House Institutional Area Sector 44, Gurgaon 122003
Any Queries	Any queries should be addressed to: Mr. Rajiv Bhatnagar Director Apparel Export Promotion Council Email: rhatnagar@aepcindia.com Mobile: +919899014590

Event Background

Tex-Trends India 2012 is the largest exhibition of Indian Textile Industry encompassing the entire value of chain of Textile Industry, starting from yarn and fabrics to High end fashion garments. Apparel Export Promotion Council has been entrusted the task of lead council to organise this exhibition along with other Textile Export Promotion Councils. **The Event would be organised either at Pragati Maidan, New Delhi OR at India Exposition Centre, Greater Noida.**

General Terms & Conditions

1. All offers should be in Indian Rupees (taxes should be mentioned separately)
2. Offer validity should upto January 2012 .
3. VAT / Service Tax Registration / Income Tax PAN, ESI and PF number should be mentioned
4. Client references and contract details for similar works executed in the past should be mentioned.
5. AEPC reserves the right to split the job work to two or more contractors without assigning any reasons

Quotation is required for	Fire Fighting Services
---------------------------	------------------------

Terms of Reference

1. Materials exhibits placed in the Halls /Open Area during the fair, which needs immediate Fire fighting equipment / cylinder to control the fire are:-
 - Wood
 - Carpet (synthetic/ woolen)
 - Electronic / Computer / Components & Machine.
 - Cotton / Fabric.

- Paper.
 - Electrical Installation
2. Random test shall be done for mock up drill to ascertain that cylinder is operational
 3. Fire extinguisher shall be placed at exit points & important locations which are easily accessible.
 4. Placard indicating the use of cylinder in case of fire shall be placed at the back of Fire extinguisher in two languages - Hindi & English.
 5. Fire extinguisher shall be placed in properly designed stand
 6. Fire extinguisher shall confirm to B.I.S.-2878,B.I.S.-934,B.I.S.-933,B.I.S.-2171
 7. In case fire extinguisher has been used by exhibitor during the fire the empty equipment must be immediately refilled or replaced by the agency after being informed.
 8. Sufficient Number of firemen in each hall shall be deputed. Each Firemen shall have Red helmet, and 'fire' written on back of the coat/ shirt. All firemen shall be trained in all type of fire control.
 9. Only firemen well trained in civil defence or those who have obtained training from a recognized fire protection institute shall be deployed on duty.
 10. No extra charges whatsoever shall be paid for night duty.
 11. Any injury to labourer / Fire men during operating/ control of fire will be responsibility of Agency. AEPC will not be responsible for any such act of operation or negligence by the agency
 12. Insurance cover, if required, shall be arranged by the Agency as the agency is responsible for such Act of negligence if any to cover insurance.
 13. Agency will co-ordinate the fire fighting service with ITPO or Expo Mart / Delhi/UP fire Service and shall work as per the rules regulation laid down by ITPO or Expo Mart and Delhi/UP Fire Act.
 14. Mock up drill will be organized from time to time for checking of alertness of Contractor Firemen on duty.
 15. The organizer would not provide any food and transportation to the agency for transfer fire personnel etc.

Rates

Following to be arranged for the duration of Fair and for Built up / Dismantling dates.

Description	Unit	Qty	Rate only	Amount (Rs.)
Water CO2 fire extinguisher 9 ltrs.	Each			
Dry Chemical powder fire-extinguisher (DCP) 5 Kg.	Each			
Mechanical foam 9 Ltrs extinguisher	Each			
Co2 fire-extinguisher 4.5 Kg	Each			
Fireman (12 Hr Duty)	Each			
Fire supervisor (12 Hr. Duty)	Each			
Bucket	Each			

Fire tender with 30,000 Ltr. water capacity with Pump & hose & firemen team. Flexible Hose, Pipe 3" dia 50 ft long with Nozzle & End connection fitting to existing fire hydrant of ITPO/Expo Mart	Per day			
Emergency Exit Battery operated	L.S			
Total				

PLEASE QUOTE SEPARATELY FOR ITPO, PRAGATI MAIDAN AND INDIA EXPOSITION CENTRE, GREATER NOIDA.

Date: _____

Authorized Signature
(Name of the Contractor with Seal)